

WATER TREATMENT DIRECTOR'S MONTHLY OPERATING REPORT December 2021

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Repaired several electrical issues at well 9 and the WWTP blower
- Adjusted SCADA power voltage at lift station 7
- Pulled aerator 15 and 16 out of the ponds for repair
- Sampled County Wide Septic
- Changed oil in screw pump
- Winter weather work
 - Snow removal and salted properties
 - Repaired salt spreader
- Removed several trees from WWTP property
- Pulled lift station 2 several times
- Replaced radio in lift station number 7

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Changed out fan motor on the booster station heater
- Took booster station pump 1 out of service for repair
- Purchased electric motor lift to move pump motor
- Loaned generator to Harrison during power outage
- Repaired the airstripper heater

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Completed George Shull's well project

Administrative Functions

During the month, the following administrative tasks were performed:

- Submitted PFAS report to EGLE
- Sent out annual billing for IPP inspection
- Submitted annual IPP report
- Conducted employee safety training
- Submitted annual storm water pollution prevention plan report