

# WATER TREATMENT DIRECTOR'S MONTHLY OPERATING REPORT January 2022

## **Wastewater Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks:

- Cleaned UV disinfection units
- Pulled lift station 2
- Replaced lift station 8 SCADA radio
- Repaired generator and replaced block heater
- Changed oil in vacuum pump
- Snow and ice removal at WWTP property
- Installed storage cabinet in WWTP bathroom

## **Water Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks:

- Commission approved chemical injection feed at booster station
- Peerless completed cleaning of well 8
  - Well was sampled and restarted
  - Voltage and chemicals were adjusted
- Installed UPC and motor at booster station
- Replaced fuses in airstripper tower
- Completed annual sampling for PFAS
- Updating pH and orthopolyphosphate monitoring to reflect EGLE requirements
- Snow and ice removal at water treatment properties

## **Landfill**

In addition to their routine duties, our Operators performed the following tasks:

- Sent in landfill report for 2021 to EGLE, Clare County Health Department, and Hatton Township

## **Administrative Functions**

During the month, the following administrative tasks were performed:

- Conducted training on Stormwater Pollution Prevention
- Submitted state reports to EGLE