

(DW)

WO#: 2103304

Date Reported: 3/10/2021

<b>CLIENT:</b>	Trace Analytical Laboratories, Inc.	<b>Collection Date:</b>	3/3/2021 1:45:00 PM
<b>Project:</b>	21C0145	<b>Received Date:</b>	3/8/2021 9:30:00 AM
<b>Lab ID:</b>	2103304-01	<b>Matrix:</b>	DRINKING WATER
<b>Client Sample ID:</b>	21C0145-01	<b>Sampled By:</b>	tq
<b>Location:</b>	Water Plant- Lab Tap		

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
<b>PFAS, DRINKING WATER</b>		<b>EPA 537.1</b>			<b>Analyst: JS</b>	
PFBS	2.6	1.9		ng/L	420	3/10/2021 1:24:00 AM
PFHxA	< 1.9	1.9		ng/L	400000	3/10/2021 1:24:00 AM
HFPO-DA	< 1.9	1.9		ng/L	370	3/10/2021 1:24:00 AM
PFHxS	5.2	1.9		ng/L	51	3/10/2021 1:24:00 AM
PFHpA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
ADONA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFOA	< 1.9	1.9		ng/L	8.0	3/10/2021 1:24:00 AM
PFOS	2.9	1.9		ng/L	16	3/10/2021 1:24:00 AM
PFNA	< 1.9	1.9		ng/L	6.0	3/10/2021 1:24:00 AM
9CI-PF3ONS	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFDA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
NMeFOSAA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
NEtFOSAA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFUnA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
11CI-PF3OUdS	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFDoA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFTTrDA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
PFTA	< 1.9	1.9		ng/L		3/10/2021 1:24:00 AM
Surr: d5-N-EtFOSSA	77.8	70 - 130		%Rec		3/10/2021 1:24:00 AM
Surr: M3HFPO-DA	83.9	70 - 130		%Rec		3/10/2021 1:24:00 AM
Surr: MPFDA	82.1	70 - 130		%Rec		3/10/2021 1:24:00 AM
Surr: MPFHxA	89.2	70 - 130		%Rec		3/10/2021 1:24:00 AM

**Qualifiers:** < Not Detected at the Reporting Limit  
 MCL Maximum Contaminant Level  
 RL Reporting Limit  
 H Holding times for preparation or analysis exceeded  
 PL Permit Limit

Original  
 Page 2 of 10